

Introduction:

INSULTECH® Acoustic Blankets are a custom fit high quality pre-engineered insulation blanket system designed to reduce harmful noise levels and improve the surrounding work environment. INSULTECH® is also capable of withstanding weather and chemical environments. INSULTECH® is flexible and easy to remove and reinstall allowing quick access and easy equipment serviceability.

Common Applications and Markets served:

INSULTECH® Acoustic Blanket Applications include; Low Temperature Process Piping, Pump Housings, Valves, Liquid Chillers, Fittings, Compressor Housings, Fan and Blower Housings, Flow Meters and Piping/Ducting. INSULTECH® Acoustic Blanket Markets include; OSHA Required Sound Limits on Equipment, HVAC Commercial, Process Industrial Markets and OEM Original Equipment Manufacturers.

Maximum Service Temperature:

This design is to act as a “SOUND ATTENUATION”, and Thermal Barrier, with a maximum service temperature of 180°F (82°C).

Product Components:

The Outer and Inner Jacket is an 18.0 oz/sq. yd. Vinyl Coated Polyester Fabric. The Insulation Material is an 11PCF Fiberglass Needled Mat-Type “E” Fiber, which acts as a sound “Absorber”. Barium Sulfate Loaded Vinyl Sheet (1lb/sf to 2lb/sf Surface Mass) is layered onto the Insulation Mat to act as a “Reflector” of sound. The “Reflector” and “Absorber” materials are encapsulated by the Vinyl Coated Polyester Fabric jacketing and sewn together, producing a self contained blanket system. The INSULTECH® Blanket System includes fasteners for easy install and removal.

Blanket Construction

Blanket construction shall be double sewn lock stitch with a minimum 7 stitches per inch. Raw jacket edges will have a tri-fold PTFE Teflon® cloth binding. No raw cut jacket edge will be exposed. Stitching will be done with PTFE Teflon® coated fiberglass thread.

Blanket Overlap

To improve sound efficiency, the blanket will extend beyond mating flanges unto existing insulation for a minimum of 2”. Where blanket cannot fit over existing oversized insulation, blanket will butt up to existing insulation with a friction fit closing seam. All sections of pipes will be insulated and open gaps are not acceptable. Blanket diameters which are 2” or larger than existing insulation must be end capped to eliminate open air void.

Leak Accommodations

To accommodate a leak and detect its origin, blankets will have a low point stainless steel or brass drain grommet or the design must incorporate a mating seam at the lowest point of the blanket.



Centrifugal Liquid Chiller
Design: LT250A-VP-1.5”
4 – 8 dBA Reduction

Blanket Insulation Weight

When designing blanket insulation for large equipment where a multi-piece construction is necessary, the total number of pieces will be minimized. Any one piece will not exceed 40 lbs. in weight.

I.D. Plate

For easy identification, a stainless steel or aluminum nameplate tag will be riveted to each blanket piece. With 1/8” embossed lettering, the nameplate will show; item location, description, size, pressure rating and tag number sequence. Each blanket will require a tag.

Quilting Pins

To enhance blanket quality and to maintain uniform thickness, Stainless Steel quilting pins will be placed at random locations no greater than 18 inches apart. Quilting pins will prevent shifting of the insulation. Stainless Steel speed washers will secure the quilting pin stem in place.

Minimized Air Void

Equipment and equipment heads are typically a multi-piece design and are installed in tag number sequence. Compressor Housings, large vessel flanges and pump housings will be designed in two half sections. Blanket design will conform to the equipment with minimized air void. All valve covers will be a two piece design with a separate body and bonnet.

Minimized Acoustic Void Leaks

All blanket pieces which match mating seams and expose hot spots, will include a 2” PTFE/Septum flap to cover the exposed seam and minimize potential noise leaks.

STANDARD FASTENER (Wiretwists & Velcro® Flaps)

A 20 gauge stainless steel wire will be doubled up and twisted in a spiral fashion, with a minimum of 4 to 5 twists per inch. Wiretwist length will be 16" or longer. The Wiretwist will be secured to the lacing pin at the pin stem. Lacing pin stems will be 14 gauge. Wiretwists will be spaced 6" on center along closing seams with matching lacing pins to lace and secure to. Velcro® hook-and-loop fasteners are sewn to an outer jacketing flap. A 2" wide hook will be stitched to the blanket and a 2" wide loop will be stitched to an extended outer jacketing flap. The flap design will include vinyl material to minimize "Hot Spots".

FASTENING OPTIONS

1) Lacing Pins - Stainless Steel Type 304 Lacing Pins. These pins will be 14 gauge. Location of pins on the blanket will be 2" or more from blanket edge and 8" or less from centerline to centerline along the blanket edge.

2) Metal "D" Ring Strap with Velcro® Tab - A multi layer fabric strap is double sewn. One strap is a 18" long pull down strap, the other is a 4" long stationary strap. Both straps are stitched to the outer jacketing of the blanket. The stationary strap includes a metal "D" Ring measuring 1.50" in width and placed ½" from the closing seam edge. The pull-down strap is placed 3" in from the closing seam edge. Both matching straps are spaced along the closing seam edge no greater than 8" apart along the blanket. The pull-down strap includes hook-and-loop Velcro®, measuring at least 1" wide by 6" long, and is box stitched to the strap surface. All closing seams have a 1.5" extended vinyl fabric flap, which is placed along the stationary strap side of the closing seam.

3) Side Release Buckles - The blanket fasteners will be 1 1/2" Polypropylene Side Release Buckles with 1.5" wide Fabric Straps. A tri-fold 1.5" (finished width) belt will be sewn together utilizing PTFE 3 ply thread. A row of stitching, along each side of the belt will be parallel for the entire length. The Buckle strap will be a minimum of 7" long and will be box stitched to the outer surface for a minimum of 5" in length. A matching pull strap will be box stitched to the outer jacket surface and will match up to the Buckle Strap. The pull strap will be a minimum of 18" long.

Assembly Drawing Requirements

Each INSULTECH® project will include an instruction package shipped with the blanket material. This package will include Assembly Drawings identifying piece location, a Material List of all pieces and Instructions for Installation on how INSULTECH® will be installed. Accurate CAD files & project records must be kept by the manufacturer. For a minimum of ten years these records will assure accuracy in re-ordering and individual parts replacement.

Production Drawing Record Keeping

The correlating Project Production Drawings will also be kept on file with the blanket manufacturer. The latest revisions, if any after installation, will be recorded on the CAD drawing system. This file will also be kept for a minimum of ten years to assure accuracy in re-orders of replacement parts.

Project Qualifications

All items to be insulated will require a field takeoff prior to bid submittal, and must be reviewed for proper cost estimation. Upon receipt of project contract, each and every item must be accurately measured for retrofitting to existing field conditions and tagged with an aluminum or stainless steel identification tag showing an item number for installation reference. At the time of installation, blankets must have corresponding item number shown on the blanket tag and must match to existing tagging on fitting. No standard blanket designs will be accepted. This will assure accurate noise reduction performance.

Warranty

We guarantee that all custom manufactured blankets will accommodate vibration probes, gauges, tubing, piping, brackets, etc. and fit correctly for optimum performance as per the design specification provided in the quotation process. In addition, for 18 months we will cover the cost of replacing the blanket should the failure be due to premature degradation of any component utilized in the blanket construction, as well as any defects due to poor workmanship.

Design Construction Sample

Upon bid submittal a blanket design sample must be presented for review and product approval. A 7"x 9" or a 2 piece 2" Gate Valve Sample will be required and must identify all characteristics mentioned in the above fabrication requirements. Any deviations from the above stated requirements may result in rejection.

Installation Guidelines

INSULTECH® will follow these simple guidelines:

- Once material is received, open boxes with care. DO NOT "cut" deep into container to avoid damaging blankets.
- Locate the Instructions for Installation.
- Follow the Material List to determine blanket part number.
- Refer to the Assembly Drawing for orientation of each blanket part number and installation details of each part.
- Locate the Identification Tag on each blanket, for correct description and sequence of blankets.
- Material is installed in tag number sequence.
- Use leather gloves to install material.
- A physical effort is required for proper placement and fit.

Storage

Once shipment is received, protect INSULTECH® Blanket Insulation from water damage and/or other abuses prior to installation. INSULTECH® Blanket Insulation will be shipped in cardboard boxes or crated for export shipping. Packaging is not designed for outdoor storage, thus a tarp or covering of some type is necessary if stored outdoor until installation is completed.

Preparation

Apply INSULTECH® Blanket Insulation on clean, dry surfaces and avoid trapping oils, greases or combustible materials.

System Reference & Test Results.....

Blanket Thickness Surface Temperature Reference:			
Operating Temperature	Thickness / Surface Temperature		Thickness / Surface Temperature
250°F (121°C)	1"	100.2°F	1.5" 92.0°F
			2" 87.4°F

- * The above referenced cold face surface temperatures should be used as guidelines for blanket thickness design.
- * The cold face surface temperature of the blanket should achieve ambient temperature conditions.
- * The economic thickness of the blanket should consider blanket cost to thermal performance.
- * Heat loss calculations are based on a 70°F ambient using a flat surface condition.

Blanket Thickness to Acoustic Performance:		
DBA Reduction Range	Thickness	Surface Mass
2 - 5 DBA	1"	1.38 - 2.38 lb/SF
6 - 10 DBA	1.5"	1.82 - 3.10 lb/SF
11 - 15 DBA	2"	2.5 - 3.51 lb/SF

- * The above DBA reductions are approximations. These figures are only guidelines of performance.
- * True estimates should include field verification of DBA levels and frequency concentrations.

Typical Product Properties Specifications

Sound Reflector	ASTM E 90-90	Test Method for Laboratory Measurement of airborne Sound Data Transmission Loss of Building Partitions & Elements Acoustic Barrier – Barium Sulfate Loaded Vinyl (.5 to 1.5 PSF)
Core Blanket	ASTM C 1086-88	Standard Specification for Glass Fiber Felt Thermal Insulation Service Temperature Up to 1200°F (649°C)
Jacketing Material	ASTM D 751-95	Standard Test Methods for Coated Fabrics Vinyl Coated Polyester Fabric - Material weight 18.0 oz/yd ² (610g/m ²) Continuous Service Temperature 180°F (82°C) Grab Tensile Strength of Fabric Warp: 460 lbs - Fill: 425 lbs.
	MIL-C-20696E	PASSED - Oil Resistance after 1 hour in Aero Shell Oil #100

Typical Applications.....



Reciprocating Compressor Enclosure

Design: LT250-VP-1.0" Thick
4 dBA Reduction



Metal Framework & Custom-Built Sound Enclosure

Design: LT250-VP-1.5" Thick
10.3 dBA Reduction

Caution

Typical industry handling practices should be exercised for the protection of the worker, such as: wear long-sleeved, loose-fitting clothing, head covering, gloves and eye protection and also appropriate respiratory protection when handling and applying material. Wash with soap and warm water after handling. Wash work clothes separately and rinse washer. For specific handling practices, refer to the product MSDS sheets for the Acoustic Blanket System.

Notes

The chemical and physical properties of INSULTECH® Acoustic Blanket represent typical average values determined in accordance with accepted test methods. The data is subject to normal manufacturing variations and is supplied as a technical service subject to change without notice. In addition, test data are average results of tests conducted under standard procedures and are subject to variation. Results should not be used for specification purposes. Design Guidelines are as follows: to access the true limitations of this recommended design, refer to the technical data for each product component. Following these guidelines will produce the highest achievable service life. Blanket design quality can be reduced or enhanced by changing any one component. If a question arises regarding deviations from those stated guidelines, or to insure the information is most current please contact your regional representative or call Shannon Enterprises direct.

